



# ELECTRICAL INSPECTION CHECKLIST - FINAL

Cayman Islands Government  
 Department of Planning  
 P.O. Box 113, Grand Cayman KY1-9000  
 Phone: (345) 244-6501 Fax: (345) 769-2922  
 Web: [www.planning.gov.ky](http://www.planning.gov.ky)

RESULT OF INSPECTION	
Pass	
Fail	
Partial Pass	

Applicant: \_\_\_\_\_ Permit No.: \_\_\_\_\_ Block & Parcel: \_\_\_\_\_

Date: \_\_\_\_\_ Site Address: \_\_\_\_\_

INSPECTION ITEMS	A	D	N A
1. Permit and approved drawings onsite			
<b>Service, Feeders, Standby systems</b>			
2. Installation de-energize and system megged - Regs.49 - 54			
3. Meter height (min 5' - 6", max. 6' - 6' AFG when attached to building) - CUC requirement			
4. Galvanize pipe for underground service; grounded - NEC 250.80			
5. Readily accessible disconnecting means - NEC 110.26, 230.6, 230.70 and EP-28			
6. Panel clearance (W30" X D36 X H6' - 6" min) - NEC 110.26			
7. Panel dedicated space - NEC 110.26 and EP-27			
8. Bonding (service only) - NEC 250.24(5), 250.(3)(A)			
9. Conductors and raceways correctly sized - NEC 220.1, 220.3, 310 and EP-34			
10. Breaker height (max 6' - 7" in the on position) - 408.4			
11. Panel cover and schedule available - NEC 408.4 and 110.22			
12. Proper wire terminations - NEC 110.14			
<b>Required Receptacle Outlets</b>			
13. General areas (2ft. or more wall space) - 210.52(A)			
14. Kitchen counters (i.e. island counters, peninsular counters) - NEC 210.52(C)			
15. Bathrooms (within 36in of each basin) - NEC 210.52(D)			
16. Laundry, garage (at least one) - NEC 210.52(F) and (G)			
17. Hallways (10ft or more) - NEC 210.52(H)			
18. Refrigerators (independent circuit) - EP-32			
19. Outdoor (front, rear & within 25ft of A/C equipment) - NEC 210.52(E)			
20. Attic (with equipment that may require servicing) - NEC 210.63			

INSPECTION ITEMS	A	D	N A
21. Water Heater (if electric or require igniter) - SPC 607.1			
22. Range (if electric or require electric igniter)			
<b>Required Lighting Outlets</b>			
23. All habitable areas and bathrooms (i.e. kitchen, living, dining, bed rm) NEC 210.70(A)(1)			
24. Hallways, stairways, exterior doors and garages - NEC 210.70(A)(2) and EP-21			
25. Storage, attics and Utility rms - NEC 210.70(A)(3)			
<b>Required Ground-fault Interrupter (GFCI) Locations</b>			
26. Bathrooms, garages, storage, work areas, outdoor and kitchens - NEC 210.8(A)(1), (2), (3) and (6)			
27. Laundry, utility and wet bar sinks (where installed within 6ft of outside edge of sinks - NEC 210.8(A)(7)			
28. Bathrooms (all circuits, outlets and switches located within) - Regs. 70			
29. Hydro-massage tubs - NEC 680.71			
<b>General (service, feeder, branch circuit, equipment)</b>			
30. Disconnecting means and panel boxes labeled and identified - NEC 110.22 and 408.4			
31. Accessible / Readily accessible disconnect(s) - NEC 110.26, 440.14			
32. Identification of conductors (i.e. No.6 or smaller) NEC 200.6, 250.119 and Regs.69			
33. Conductors and overcurrent protection (correctly sized) - NEC 220, 240, 310 and EP-23			
34. Listed and proper rated equipment and devices - NEC 110.2, EP-42			
35. Smoke detectors (AC/DC & interlinked) - EP-37			
36. Neat workmanship - NEC 110.12			
37. Permanent provision for cooking and water heater installed			
38. Installation de-energize, temporary wiring removed and all panel covers installed			

Note: This form is intended as a general checklist and is not intended to address all possible conditions of approval;

A = Approved, D = Disapproved, NA = Not applicable

Notes: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\_\_\_\_\_  
 ELECTRICAL/BUILDING INSPECTOR

\_\_\_\_\_  
 ELECTRICAL CONTRACTOR